

**Former J.B. Sims Generating Station**

**CCR Units 1/2 Impoundment and Unit 3A/B Impoundments**

**Notification of Initiation of Assessment of Corrective Measures 40 CFR §257.96 and  
Michigan Part 115 R 299.4441(g)**

**May 1, 2024**

Pursuant to 40 CFR §257.96 and Michigan Part 115 R 299.4441(g) , this serves as the notice that an assessment of corrective measures has been initiated at the Former J.B. Sims Generating Station for Units 1/2 Impoundment and Unit 3A/B Impoundments. The Former J.B. Sims Generating Station is located at 1231 North 3rd Street, on Harbor Island, in Grand Haven, Michigan. As documented in the 2023 Annual Groundwater and Corrective Action Report, placed into the facility operating record on January 31, 2024, statistically significant levels of Appendix IV constituents of interest that exceeded groundwater protection standards were detected at monitoring wells associated with both CCR units. Therefore, in accordance with 40 CFR §257.96 and Michigan Part 115 R 299.4441(g), the assessment of corrective measures was initiated for the CCR ash impoundments on May 1, 2024. The groundwater will continue to be monitored in accordance with the assessment monitoring program as specified in 40 CFR §257.95 and Michigan Part 115 R 299.4441.